

## WELL INSPECTION REPORT

ADWR Well Registration No.: 55-548880 (House Well)  
Well type: Exempt

Date of NOI Application: 4/28/1995

Date of inspection: 6/22/2016

Drilled by: Doug Slade Drilling Co.  
PO Box 398  
Springerville, AZ 85938  
(928) 245-1539

Inspected by: R. Davis Drilling LLC  
PO Box 1427, Springerville, AZ 85938  
(928) 245-0230

Well owner: James W. Crosswhite  
PO Box 44, Nutrioso, AZ 85932  
(928) 339-4840

Well location: House 20, CR2112, Nutrioso, AZ  
N33\*58.362', W109\*12.260'  
T7N, R30E, Section 29  
Parcel ID #: 102-43-002D Apache County

Primary Use: Domestic

Casing type and diameter: 6" PVC perforated 60-100 ft

Total well depth: 100 ft (water level 52 ft)

Static water level: 20 ft

Pump rating (HP and flow): Grundfos 1/2 hp/5 amp/ 10 gpm pump/set 86 ft

Pressure tank capacity: 80 gallon tank

Overall mechanical condition: OK

Overall visual condition: OK

Well flow rate: 12 gpm

Total well drawdown: 37 feet

Clarity of water: clear

Additional Remarks: Performed two tests of 3 hours each with similar static, drawdown, and flow results.